SUPPORTED SCAFFOLD CHECKLIST

Project:	Inspected by:	Date:			
Scaffold Location:		Supervisor:			
The following items should be visually checked prior to working on scaffolding. If during the inspection a defect or damage to the scaffold is discovered, the scaffold must be tagged out and not used until repairs are made. Report defect or damage immediately to the Project Superintendent or Foreman.					
			YES	NO	N/A
Has a competent pe Green tag posted in	erson inspected the scaffold before each dicating ready to use?	work shift, and is there a			
Scaffolds should be	set on sound footing.				
Scaffolds have not b	peen altered.				
All scaffolds are fully	y planked with gaps between the plankin	g no wider than one inch.			
Scaffold planks must than 12 inches.	st extend over their end supports not less	than 6 inches nor more			
Are guardrails, and	planking in place and secure?				
Are toe boards insta	alled or other means in place to guard ag	ainst falling objects?			
Are locking pins at j	oints in place?				
Is there an access ladder or other safe access?					
Scaffolds should no	t be loaded with more weight than they w	vere designed to support.			
Scaffold platforms must be at least 18 inches wide.					
•	on provided on a scaffold exposed to over				
Do not change or re	move scaffold members unless authorize	ed.			
Scaffolds are not en	ected or moved within 10 feet of power li	nes.			
	permitted to work on scaffolds in bad wear person has determined that it is safe to				
Ladders, boxes, bar work height.	rels, buckets or other makeshift platform	s are not used to raise			
Extra material is not	allowed to build up on scaffold platforms	6.			
Are at least two corr	ners of the base plates nailed to the mud	sills?			
Notes:					
					_